



GENERAL NOTES: (APPLIES TO ALL SHEETS)

UTILITY WARNING

The Contractor is advised that existing overhead and underground utilities such as (but not limited to) electrical lines and poles, telephone cable, gas lines, water lines, and sanitary sewers exist in the rights-of-way where the proposed improvements are to be installed, all in accordance with the provisions of R.S. 38:2223. It shall be the Contractor's responsibility to protect these existing utilities during the construction of the work to be installed under this Contract and any damage to the existing utilities caused by the negligent acts of the Contractor shall be repaired by the Contractor at his expense. The Contractor shall contact Louisiana One (1) Call (1-800-272-3020) a minimum of 48 hours prior to beginning construction in the work area.

- ALL HARD SURFACE ROADS, AND STATE HIGHWAYS SHALL BE BORED WITH H.D.P.E. DR9 WATER SERVICE LINES.
- ALL HARD SURFACE DRIVES SHALL BE BORED WITH H.D.P.E. WATER SERVICE LINES.
- STATE HIGHWAY PERMIT WILL BE OBTAINED BY OWNER.
- FINAL LOCATIONS OF NEW WATER SERVICES AND LINES WILL BE DETERMINED AFTER UTILITIES ARE LOCATED BY THE CONTRACTOR. SIZE, LOCATION AND DEPTH OF EXISTING WATER MAINS AND SERVICES TO BE FIELD VERIFIED BY THE CONTRACTOR.
- CLEAR AS NECESSARY FOR WATER SERVICES PLACEMENT. (NO DIRECT PAY)
- WATER MAINS SHALL BE DISINFECTED PER LAC 51:XII.353.A.
- THE MINIMUM HORIZONTAL AND VERTICAL SEPARATION OF 6 FEET AND 18 INCHES, RESPECTIVELY, WILL BE MAINTAINED BETWEEN THE OUTSIDE EDGE OF WATER MAINS AND THE OUTSIDE EDGE OF ANY SEWER MANHOLES, WET WELLS, FORCE MAINS, AND GRAVITY MAINS.
- TYPICAL NEW SERVICE  
BRASS SADDLE - MUELLER H-13000  
3/4" CORPORATION VALVE - MUELLER H-15008N  
SERVICE LINE - 3/4", 1", OR 1 1/2" DR9, HDPE, - AWWA C901  
3/4" CURB STOP WITH LOCK - MUELLER B-24350N  
3/4" DUAL CHECK VALVE - MUELLER H-14242N  
METER BOX - DFW PLASTICS DFW1200TT WITH LOCATABLE LID



|      |                       |     |       |                |     |
|------|-----------------------|-----|-------|----------------|-----|
| 4/19 | FINAL OWNER REVIEW    | TAA |       |                |     |
| 2/19 | OWNER REVIEW          | TAA |       |                |     |
| 1/18 | ISSUED FOR DHH REVIEW | TAA | 03/20 | ISSUED FOR BID | TAA |
| DATE | REVISIONS             | BY  | DATE  | REVISIONS      | BY  |

WATER WORKS DISTRICT NO. 3  
OF ST. TAMMANY PARISH  
OWNER

CONTRACT NO. 4-EXISTING WATER DISTRIBUTION SYSTEM IMPROVEMENTS  
INDEX MAP  
TITLE

|               |                     |
|---------------|---------------------|
| DESIGNED: TAA | SCALE: 1" = 400'    |
| DRAWN: CHB    | DATE: FEBRUARY 2019 |
| CHECKED: BGH  |                     |
| APPROVED: BGH |                     |

**PEC** PROFESSIONAL ENGINEERING  
CONSULTANTS CORPORATION  
7600 Innovation Park Dr. | Baton Rouge, LA 70820 | 225.769.2810

PROJECT NO. 10280-4  
SHEET NO. 2